

थ 濟 部 局

BUREAU OF STANDARDS, METROLOGY AND INSPECTION, MINISTRY OF ECONOMIC AFFAIRS



品驗證登錄證

CERTIFICATE OF THE REGISTRATION OF PRODUCT CERTIFICATION

證書號碼: CI417060241450 號 00

Certificate No.

兹據 東元電機股份有限公司湖口廠 申請驗證登錄,經審查結果符合規

定,准予登錄並使用商品安全標章 及識別號碼:

R41024 。 其登錄事項如下:

The application made by

TECO ELECTRIC & MACHINERY CO.,LTD.HU-KOU PLANT

for Registration of Product

Certification has been reviewed and found to be in compliance with related regulations. Therefore, registration is granted with the

Product Safety Mark and the Identification No.

R41024

. Details of the registration are follows:

申 請 人: 東元電機股份有限公司湖口廠

統一編號: 11332202

Applicant

Uniform No.

地 址:新竹縣新竹工業區中華路15號

Address

生產廠場: 詳如附表

Factory

址:詳如附表

Factory Address

商品種類名稱:

Type/name of product

商品分類號列: 8536.20.49.00.6

C. C. C Code

中文名稱: 無熔線斷路器

Chinese name

英文名稱 : MOLDED CASE CIRCUIT BREAKER

English name

式: QCS 1P Ui:440VAC 60Hz 100AF(15/20/30/40/50A) Icu:10kA at 110V; Ics:5kA

at 110V

詳如附表 系列型式:

Series of the type

依據標準 : CNS14816-2 (093年版)、符合CNS 15663第5節「含有標示」規定 102年版

Standards

標準檢驗局新竹分局發證(發證地址:300新竹市東區民族路109巷14號)

This certificate is issued by the BSMI. (Hsinchu branch: No.14, Ln. 109, Minzu Rd., East Dist., Hsinchu City 300, Taiwan)

登錄日期:中華民國 107 年 09 月 06 日 Registration Date 2018 (year) 09 (month) (day) 本證書有效期限至 110 09 05 日 Expiration Date 2021 09 05 (year) (month) (day) 發證日期:中華民國 107 年 08 09 A H -2018 09 Date of issue 08 (year) (month) (day)

註1:持本證書進口驗證登錄商品時,進口人須與本證書名義人相同。

註2:次年度商品驗證登錄年費繳納期限為當年11月30日,逾期未繳納者,經限期繳納屆期 未繳納,即依商品檢驗法第42條第7款規定廢止驗證登錄,並自次年度1月1日起生效。





經濟部標準檢驗局 BUREAU OF STANDARDS,METROLOGY AND INSPECTION, MINISTRY OF ECONOMIC AFFAIRS

商品驗證登錄證書

CERTIFICATE OF THE REGISTRATION OF PRODUCT CERTIFICATION

證書號碼: CI417060241450 號 00

Certificate No.

系列型式: QCS 1P Ui:440

QCS 1P Ui:440VAC 60Hz 100AF(15/20/30/40/50A) Icu:10kA at 220V ; Ics:5kA at 220V


Series of the type

QCS 2P Ui: 440VAC 60Hz 100AF(15/20/30/40/50/60/75/100A) Icu: 10kA at 220V ; Ics: 5kA at

220V

QCS 3P Ui:440VAC 60Hz 100AF(15/20/30/40/50/60/75/100A) Icu:10kA at 220V ; Ics:5kA at 220V,

(以下空白)



經濟部標準檢驗局 BUREAU OF STANDARDS,METROLOGY AND INSPECTION, MINISTRY OF ECONOMIC AFFAIRS

商品驗證登錄證書

CERTIFICATE OF THE REGISTRATION OF PRODUCT CERTIFICATION

證書號碼: CI417060241450 號 00

Certificate No.

生產廠場: 1. 東元電機股份有限公司湖口廠

Factory: 新竹縣新竹工業區中華路15號

2. Taian (Subic) Electric, Inc.
Phase 1 Subic Bay Industrial Park Argonaut Highway
Comer Brave Heart St. Subic Bay Freeport Zone, Zambales
Philippines

(以下空白)

